



2000 I-30 E
Greenville, TX 75402

Monday, November 10, 2025

County: Rains County

Farmers Electric Cooperative Member: AMANDA ROTH
Service Order Number: 2025106538

Greetings:

Farmers Electric Cooperative, Inc. is requesting permission to construct electrical power distribution facilities which will cross RS CR 3445.

Site location map/construction sketches are attached. The construction sketch details the proposed work. The proposed electrical service will be constructed:

- Overhead - All road crossings will have a minimum vertical clearance of 22 feet.
- Underground - All underground bore crossings are PVC encased 4' of coverage from the lowest point of the Right of Way.

If you have any questions, please contact me at any time.

Sincerely,

Shaya Smith
ssmith@farmerelectric.coop
Engineering Coordinator

Enclosures


County Approval Section:

Approved: _____ Denied: _____

Authorized Signature: _____ Date: _____



2000 I-30 E
Greenville, TX 75402





**COUNTY OF RAINS
ROAD & BRIDGE ADMINISTRATION**



1293 S. State Highway 19
P.O. Box 185
Emory, Texas 75440
Phone (903) 473-5099 Fax (903) 473- 5070
Ronnie.morgan@co.rains.tx.us
Road and Bridge Administrator

November 10, 2025

Farmers Electric Cooperative
2000 Interstate 30 East
Greenville, Texas 75402-9084
Attn: Ms. Shaya Smith
Project Coordinator

Dear Ms. Williams:

RE: Notice of Proposed Construction across Rains County Road 3445 for FEC Member Amanda Roth and Work Order No. 2025106538 as shown by sketches sent to us. All road crossings will have a minimum vertical crossing of twenty-two (22) feet.

It is expressly understood that Rains County does not purport, hereby, to grant any right, claim, title, or easement in or upon the right-of-way. A permit is hereby granted for continuous use with the following conditions:

1. All work within County Road right-of-way shall be performed in accordance with County instructions. Areas trenched within the road right-of-way for the installation of utility lines/cables or other services must be returned to their original condition. The installation of any utility shall not damage the roadway and adequate provisions must be made to cause minimum inconvenience to traffic and adjacent property owner.
2. All water and gas lines across County Roads shall be bored and encased, all other utility installations shall be bored:
3. The owner, his heirs or assigns shall bear expense of removal or relocations should Rains County require same for purposes of improving or widening the road, or in the event said road shall become a Farm-to-Market Road or Highway.
4. Rains County, its employees, agents, or assigns will be held harmless of all claims, actions or damages of every kind and description which may accrue to be suffered by

any person or persons, corporation or property by reason of the performance of any such work, character of materials used or manner of any installation, maintenance or operation or by improper occupancy or right-of-way or public place or public structure, and in case any suit or action is brought against Rains County for damages arising out of reason of any of the above causes.

5. Farmers Electric Cooperative (Grantee), its successors or assigns will be upon notice to him or them of commencement of such action, defend the same at this or their own expense and will satisfy any judgment after said suit or action shall have finally determined if adverse to Rains County.
6. Rains County, its employees and agents will at no time be held liable for any damage or injury done to property of Farmers Electric Cooperative (Grantee), whether in contract or in tort, which may result from improving and/or maintaining county roads; and
7. The job superintendent must contact Rains County Road and Bridge Administrator to schedule a meeting at the job-site 48 hours prior to commencing work The Administrator, Ronnie Morgan can be contacted at (903) 473-5099 (8:00 a.m. 4:00 p.m.)

**Approved by Rains County Road and Bridge Administrator this November 10, 2025.
The construction crew should have a copy of this letter in it's possession during construction.**

Regards,

Ronnie Morgan

Rains County Road and Bridge Administrator

RM/CHP



2000 I-30 E
Greenville, TX 75402

Monday, November 17, 2025

County: Rains County

Farmers Electric Cooperative Member: LUIS IBARRA
Service Order Number: 2025106544

Greetings:

Farmers Electric Cooperative, Inc. is requesting permission to construct electrical power distribution facilities which will cross County Road 2245 AT POLE 069506 WHICH IS 347' E OF FM 779.

Site location map/construction sketches are attached. The construction sketch details the proposed work. The proposed electrical service will be constructed:

- Overhead - All road crossings will have a minimum vertical clearance of 22 feet.
- Underground - All underground bore crossings are PVC encased 4' of coverage from the lowest point of the Right of Way.

If you have any questions, please contact me at any time.

Sincerely,

Psalm Harper
pharper@farmerelectric.coop
Engineering Coordinator

Enclosures

County Approval Section:

Approved: _____ Denied: _____

Authorized Signature: _____ Date: _____



+

COUNTY OF RAINS ROAD & BRIDGE ADMINISTRATION

1293 S. State Highway 19
P.O. Box 185
Emory, Texas 75440
Phone (903) 473-5099 Fax (903) 473- 5070
Ronnie.morgan@co.rains.tx.us
Road and Bridge Administrator



November 19, 2025

Farmers Electric Cooperative
2000 Interstate 30 East
Greenville, Texas 75402-9084
Attn: Ms. Psalm Harper
Project Coordinator

Dear Ms. Harper:

RE: Notice of Proposed Construction across Rains County Road 2245 for FEC Member Luis Ibarra and Work Order No.2025106544 as shown by sketches sent to us. All road crossings will have a minimum vertical crossing of twenty-two (22) feet.

It is expressly understood that Rains County does not purport, hereby, to grant any right, claim, title, or easement in or upon the right-of-way. A permit is hereby granted for continuous use with the following conditions:

1. All work within County Road right-of-way shall be performed in accordance with County instructions. Areas trenched within the road right-of-way for the installation of utility lines/cables or other services must be returned to their original condition. The installation of any utility shall not damage the roadway and adequate provisions must be made to cause minimum inconvenience to traffic and adjacent property owner.
2. All water and gas lines across County Roads shall be bored and encased, all other utility installations shall be bored:
3. The owner, his heirs or assigns shall bear expense of removal or relocations should Rains County require same for purposes of improving or widening the road, or in the event said road shall become a Farm-to-Market Road or Highway.
4. Rains County, its employees, agents, or assigns will be held harmless of all claims, actions or damages of every kind and description which may accrue to be suffered by

any person or persons, corporation or property by reason of the performance of any such work, character of materials used or manner of any installation, maintenance or operation or by improper occupancy or right-of-way or public place or public structure, and in case any suit or action is brought against Rains County for damages arising out of reason of any of the above causes.

5. Farmers Electric Cooperative (Grantee), its successors or assigns will be upon notice to him or them of commencement of such action, defend the same at this or their own expense and will satisfy any judgment after said suit or action shall have finally determined if adverse to Rains County.
6. Rains County, its employees and agents will at no time be held liable for any damage or injury done to property of Farmers Electric Cooperative (Grantee), whether in contract or in tort, which may result from improving and/or maintaining county roads; and
7. The job superintendent must contact Rains County Road and Bridge Administrator to schedule a meeting at the job-site 48 hours prior to commencing work The Administrator, Ronnie Morgan can be contacted at (903) 473-5099 (8:00 a.m. 4:00 p.m.)

**Approved by Rains County Road and Bridge Administrator this November 19, 2025.
The construction crew should have a copy of this letter in it's possession during construction.**

Regards,

Ronnie Morgan

Rains County Road and Bridge Administrator

RM/CHP